

Improvement in gas sensitivity of ZnO thin film by doping with Ti

**تحسين حساسية أغشية الرقيقة للمركب
Zno المطعم بنسب مختلفة من عنصر Ti**

Mohammed A. Kadhim

University of Karbala, College of Science, Department of Physics

malmengushi@gmail.com

Abstract

In this work, we explore immaculate and doped ZnO films with Ti for CO gas detecting. Immaculate and doped ZnO layers have been manufactured by Pulsed Laser deposition procedure (PLD) with different doping proportion. Structure and morphological properties have been studied by XRD and AFM to concentrate on the parameters that enhance the gas detecting. Pure ZnO films and Low doping with Ti at room temperature indicating low affectability. Expanding the working temperature and dopant proportion prompts expanding the responsiveness and lessening stall the reaction time and recuperation time.

Keywords: PLS method; XRD diffraction; AFM analysis; Heartbeat Laser; ZnO Layer

الخلاصة :

في هذا العمل البسيط تبين لنا بتطعيم أغشية المركب ZnO بنسب مختلفة لعنصر Ti لكشف غاز أوكسيد الكربون CO . قد تم تطعيم الاغشية الرقيقة للمركب ZnO بواسطة جهاز (PLD ترسيب الليزر النبضي) وبنسب وزنيه مختلفة من عنصر التيتانيوم Ti ، اجريت فحوصات حيود الاشعة السينية XRD و كذلك فحوصات AFM لمعرفة الخصائص التركيبية على الاغشية النقية والمطعمة وبدرجات حرارة مختلفة والتي أسهمت في تعزيز الكشف على الغاز ، كانت الاستجابة ضعيفة للاغشية النقية وكذلك المنخفضة التركيز بينما ازدادت الاستجابة ونقصان وقت رد الفعل وكذلك نقصان وقت الاستعادة عند زيادة التطعيم بعنصر Ti

Introduction

The straightforward operation gadget, solidness and high affectability, chemiresistors taking into account metal-oxides such ZnO, SnO₂ are utilized as gas sensors for different applications.^[1, 2]

In resent years, there is a magnificent excitement for assembling recognizing contraptions to push protection from the risk of used gasses as a piece of industry. Slight movies gas sensor broadly utilized in light of the fact that its quick reaction, and ease^[3]. A gas detecting instrument incorporates semiconducting materials resistivity changes by chemisorbed of gas particles on its surface in light of the fact that the adjustment in control bearer fixation. In n-sort semiconductor the collaboration with a lessening gas prompts an expansion in conductivity happens. While, an oxidizing gas brought on an exhaust in control conveying, bringing about a lessening in conductivity. In p-sort semiconductor inverse impacts are seen with the material in light of the fact that the gaps being the dominant part charge transporters^[4]. Beat laser statement (PLD) technique used to get ready flimsy films by the removal of one or more targets lit up by a centered beat laser shaft^[5]. Zinc oxide (ZnO) is an important electronic and photonic material because of its wide-bind semiconductor with a band gap of about to 3.37eV and large exciton binding energy of 60meV of excitons at room temperature^[6-8].

ZnO can exist in three phases (a) hexagonal (wurtzite)^[9] (b) zinc-blend^[10] (c) rock salt [10]. The most stability ZnO structure is hexagonal (wurtzite) as shown in figure (1-2) with lattice parameters a=0.325nm and c=0.521nm

Experimental

The set-up for PLD is appeared in Fig. 1. At (10-2) mbar vacuum chamber, ZnO focuses with various doping proportion with Ti are barrage by a beat laser shaft with 45°. The removed molecules are kept on glass substrates parallel to the objective.




Fig. (1) Schematic for PLD set-up

All films were inspected by X-ray diffraction and nuclear power microscopy. The front contacts were saved with Aluminum (Al) by means of metal veil by warm vanishing procedure.

The Schematic for utilized set-up to test the chemo resistive of gas sensor is appeared in Fig.(2) to test the responsively of the examples to CO gas. The example was stacked in a shut chamber and the electrical resistance of the sensor was measured by a multi-meter associated with PC when an around 10% of target gas was stream with air into the load in (on) and (off) instance of target gas stream.




Fig. (2) Schematic for used setup of Gas sensor system.

Results and discussion

Fig.(3) Demonstrates the XRD for unadulterated and doped ZnO films, this figure demonstrates that all films have poly crystalline ZnO structure. Table (1) demonstrates the information for the first three crests situated at $2\theta = 31.760^\circ$, 34.430° and 36.272° relating to (100), (002) and (101) directions. The doping prompts little move into crest position toward high values as an aftereffect of diminishing the cross section separating because of present Ti particles inside it. We can likewise see that the doping prompts expanding in full width half greatest for tops, i.e. diminishing the crystal size for precious stones.




Fig. (3) X-ray diffraction designs for immaculate and doped ZnO films with various dopant proportion with Ti.

Table (1) X-ray diffraction information for the initial three crests for immaculate and doped ZnO films with various dopant proportion with Ti.

Ti %	2θ (Deg.)	FWHM (Deg.)	d _{hkl} Exp.(Å)	G.S (nm)	hkl	d _{hkl} Std.(Å)	Phase	Card No.
0	31.760	0.700	2.8152	11.8	(100)	2.8137	ZnO	96-901-1663
	34.430	0.643	2.6027	12.9	(002)	2.6035	ZnO	96-901-1663
	36.272	0.782	2.4747	10.7	(101)	2.4754	ZnO	96-901-1663
2	31.812	0.770	2.8107	10.7	(100)	2.8137	ZnO	96-901-1663
	34.482	0.707	2.5989	11.8	(002)	2.6035	ZnO	96-901-1663
	36.324	0.860	2.4712	9.7	(101)	2.4754	ZnO	96-901-1663
4	31.874	0.847	2.8054	9.8	(100)	2.8137	ZnO	96-901-1663
	34.544	0.778	2.5944	10.7	(002)	2.6035	ZnO	96-901-1663
	36.436	0.946	2.4639	8.8	(101)	2.4754	ZnO	96-901-1663
6	31.939	0.932	2.7998	8.9	(100)	2.8137	ZnO	96-901-1663
	34.609	0.856	2.5897	9.7	(002)	2.6035	ZnO	96-901-1663
	36.501	1.041	2.4597	8.0	(101)	2.4754	ZnO	96-901-1663

Fig. (4) Shows the three dimensional atomic force microscopy images. The calculated diameter for particles arranged in table (2). This table shows that the average diameter decrease with increasing doping ratio.




Fig. (4) AFM image for pure and doped ZnO films with different dopant ratio with Ti.

Table (2) AFM parameters for pure and doped ZnO films with different dopant ratio with Ti.

Sample	Avg. Diameter (nm)	RMS roughness (nm)	Peak-peak (nm)
Pure ZnO	105.78	0.15	0.8
2% Ti	95.43	2.84	12.0
4% Ti	90.12	3.90	19.3
6% Ti	89.54	4.16	22.5

Fig. (5) shows the variation of sample resistivity for pure ZnO film, with time in case of (ON) and (OFF) of target gas flow at different temperature. This figure shows that the variation of resistivity increase with increasing temperature as result of increasing of gas adsorbed on sample surface. The values of Responsivity, response time and recovery time were arranged in both tables (3) and (4) with different concentration Ti and temperature respectively.




Fig. (5) Variation of sample resistance in case of CO gas on and gas off for pure ZnO sample at different temperature.

Table (3) Responsivity, response time and recovery time for pure ZnO sample to CO gas at different temperature.

Temperature(⁰ C)	Responsivity%	response time (s)	recovery time(s)
RT	9.821	33	27
50	15.486	32	29
100	14.583	32	22
150	18.181	34	23
200	22.907	32	28
250	45.606	18	26

Fig. (6) Shows the variation of sample resistivity for pure and doped ZnO films, with time in case of (ON) and (OFF) of target gas flow.




Fig. (6) Variation of sample resistance in case of CO gas on and gas off for pure and doped ZnO with Ti.

Table (4) Responsivity, response time and recovery time for for pure and doped ZnO with Ti.

Doping ratio	responsivity	response time (s)	recovery time(s)
Pure	45.75464	23	30
2%	58.24745	21	29
4%	66.98115	19	28
6%	79.27921	20	33

Conclusions

The responsivity for immaculate ZnO thin film to CO gas increment with expanding temperature. It has been enhanced the ZnO sensor by doping with Ti, where unmistakably demonstrates an expansion of responsivity to CO gas and lessening reaction time and recuperation time with expansion doping proportion with Ti

References

- [1] D. Williams, "Sensors and Actuators ", 57, 1 , 1999.
- [2] H. Shokry, A. Kashyouta, , I. Morsib, A. Nasserb, I. Alib, " Synthesis, characterization and fabrication of gas sensor devices using ZnO and ZnO:In nanomaterials, Beni-Suef University Journal of Basic and Applied Sciences, Volume 3, Issue 3, September 2014, Pages 216–221
- [3] A. Wisitsoraat and A. Tuantranont, "Gas-Sensing Characterization of TiO₂-ZnO Based Thin Film," IEEE SENSORS, pp. 964–967, 2006.
- [4] G. Fine, L. Cavanagh, A. Afonja, and R. Binions, "Metal oxide semi-conductor gas sensors in environmental monitoring," Sensors, vol. 10, no. 6, pp. 5469–5502, 2010.
- [5] H. Krebs, M. Weisheit, S. Erik, T. Scharf, C. Fuhse, M. St, K. Sturm, M. Seibt, H. Kijewski, D. Nelke, E. Panchenko, and M. Buback, "Pulsed Laser Deposition (PLD) - a Versatile Thin Film Technique UHV-chamber," Adv. Solid State Phys. SE - 36, pp. 505–518, 2003.
- [6] A.D.A. Buba and J.S.A. Adelabu, Optical and Electrical Properties of Deposited ZnO Thin Films, The pacific Journal of Science and Technology.11 (2010) 429-434.
- [7] D. Cornejo Monroy, J.F. Sanchez-Ramirez, M.Herrera-Zaldivar and u. Pal,Effect of Deposition parameters on the Optical and Microstructura Characteristics of Sputtered deposited nanocrystalline ZnO Thin Films, Revista Mexicana De Fisica. 53(2007),23-28.
- [8] R.Sharma, P.K. Shishodia, A. Wakahara and R.M. Mehra,Investigations of Highly Conducting and Transparent Sc Doped ZnO Films Grown by the Sol-gel process, Materials cience- Poland. 27(2009),225-237.
- [9] J. Dean "Lange`s Handbook of chemistry" Hill Book Company,(1980).
- [10] Y.F.Mei, G.G.Siu, Ricky K.Y.Fu, Paul K.Chu,Z.M. Li, Z.K. Tang, Room-temperature electrosynthesized ZnO thin film with strong (002) orientation and its optical properties, Applied Surface Science. 252 (2006) 2973-2977.